

# Central Plant Electrification and Campus Decarbonization Through CEOP



Director of Central Plant Operations and Strategic Energy Projects www.csudh.edu/sustainability



#### Final GHG Reduction in CEOP



### **OUR CSUDH Energy Journey- Projects**

Project	Location	Date Completed	
Switched from Gas Fired Absorption Chillers to Electric	Central Plant (CP)	2019 Q2 +↑	
LED w Enlighted controls integrated into the BAS (Building Automation System)	Social Behavior Sciences (SBS) Welch Hall (WH) La Corte Hall (LCH)	2020 2021 2021	
VAV dual duct Pneumatic to DDC	SBS	2020 Q2	
Finish CHW, HW Belimo Smart Energy Valve upgrade	Campus wide	2020 Q4	
964 kW roof top solar (WH,SCI, S Lib, SBS, Gym)	Campus wide	2022 Q1	
800 exterior fixtures with LED & controls	Entire campus exterior	2022 Q2	
Solar Thermal HW	CP Boiler roof	2022	
70ton Trane (gas heating) to 25t & 12.5T heat pump	South Academic Complex #3 (SAC-3)	2023	
Heat pumps 21-30t MultiStack units	Cental Plant (CP)	2024 Q3	
facil.ai (Artificial Intelligence for Central Plant Optimization)	Central Plant (CP)	2023 Q4	
LED Englighted/ BAS Integration- Pneumuatic to DDC	Student Health Center	2025 Q2 Planned	
LED Enlighted	Physical Plant	2025 Q2 Planned	
200 LV 2 EV Chargers	Lot 3	2026 Q3 Planned	
More Solar 2 MW to 3 MW	Carport and Ground Mount	2025/2026 Planned	




Decarbonization @ California State University, Dominguez Hills

- Campus has NetZero Vision
- 1 MW of Solar in Place
- 4 MWH of battery Storage in place
- 2,000 Tons of Gas Fired absorbers replaced with 3,000 Ton of York Centrifugal chillers
- Campuswide LED and Enlighted controls (smart fixture controls)
- Pneumatic to DDC
- Electrification of space heating
- Al Chiller Optimization



#### CEOP Journey – GHG Reduction











#### **Heat Map**



















#### Summary of Major Equipment

- 21, 30-Ton Multi-stack Modules packaged into 7-skids
- 3, 10 HP Chilled water pumps, 500 GPM each
- 3, 10 HP Hot water Pumps, 500 GPM each
- Net Electrical Installed Load Addition: 1.35 MVA
- 12 KV/480 V 1.5 MVA Transformer
- 2500 Amp, 480 V Switchboard




#### Heating Demand Time Duration Curve






#### CSUDH Gas Meters Main & Central Plant



### Chiller Plant Efficiency (2024 to Previous Years)



## **Central Plant Utility Cost Trend**

Year	Total kWh (Chillers +	<b>Total Gas Therms</b>	kW	h Cost @ \$0.27	Th	erm Cost @ \$1.11	Annı	ial CUP Cost	GSF
	Heat Pumps)								1.3 mil (2019)
2020	2,060,032	208,693	\$	556,209	\$	231,650	\$	787,858	1.4 mil (2020)
2021	2,237,098	169,369	\$	604,016	\$	188,000	\$	792,016	1.6 mil (2021)
2022	2,849,753	178,851	\$	769,433	\$	198,524	\$	967,958	
2023	1,979,124	212,813	\$	534,364	\$	236,223	\$	770,586	
2024	2,008,706	116,022	\$	542,351	\$	128,784	\$	671,135	
2025	2,608,103	6,584	\$	704,188	\$	7,308	\$	711,496	

- 2020 was COVID with much less people. It has been increasing every year since
- Al experimentation mid 2023. Perfected late 2024
- 21qty 30ton (630tons) Heat Pumps implemented mid 2024
- Utility bill actually dropped by pairing AI with Heat Pumps



If Better is Possible, Good is not Enough

We're just getting started

**Kenny Seeton (Kenergy)** 

Director of Central Plant Operations and Strategic Energy Projects
<a href="mailto:kseeton@csudh.edu">kseeton@csudh.edu</a>

Q&A/Discussion

